



MEGHALAYA POWER LIMITED

Lumshnong, Meghalaya


Date (DD-MM-YYYY)	Pressure (mmHg)	Relative Humidity (%)	Temp. (C)	Manual Rain (mm)
01-10-2023	762.8	81.2	28.7	0.0
02-10-2023	762.8	83.3	30.4	62.8
03-10-2023	761.8	84.8	30.8	9.2
04-10-2023	763.8	70.3	31.8	0.0
05-10-2023	764.8	68.3	28.6	18.6
06-10-2023	762.8	68.3	22.8	34.0
07-10-2023	761.8	75.7	23.8	68.0
08-10-2023	763.8	74.2	25.8	90.8
09-10-2023	763.0	78.9	26.8	21.8
10-10-2023	762.8	77.3	30.8	0.0
11-10-2023	764.3	74.2	30.3	0.0
12-10-2023	763.2	70.6	29.5	2.0
13-10-2023	763.6	90.2	30.2	0.0
14-10-2023	762.2	76.4	29.5	0.0
15-10-2023	762.5	72.2	27.2	0.0
16-10-2023	763.2	79.4	30.9	0.0
17-10-2023	763.8	84.8	30.8	0.0
18-10-2023	764.3	70.3	31.8	0.0
19-10-2023	761.8	68.3	28.6	0.0
20-10-2023	764.0	68.3	22.8	0.0
21-10-2023	761.8	75.7	23.8	0.0
22-10-2023	763.8	74.2	25.8	0.0
23-10-2023	763.0	78.9	26.8	12.6
24-10-2023	762.8	77.3	30.8	4.2
25-10-2023	764.3	74.2	30.3	0.0
26-10-2023	763.2	70.6	29.5	0.0
27-10-2023	763.6	90.2	30.2	0.0
28-10-2023	762.2	76.4	29.5	0.0
29-10-2023	762.5	72.2	27.2	0.0
30-10-2023	763.2	79.4	30.9	0.0
31-10-2023	763.6	72.2	27.2	0.0
			Total	324.0

	MEGHALAYA POWER LIMITED (43MW) Lumshnong, Meghalaya		Reference No.	MPL/Env/F – 01
			Issue No.	1
			Date of Issue:	24.08.2013
			Revision No.	5
	AMBIENT AIR QUALITY MONITORING REPORT		Date of Rev.	01.12.2020
Reference No.: MPL (43 MW)/ENV/AAQM/MONTHLY/2023-24/07			Month : October	
Location of Sampling: Near ADM Office (South)		GPS Coordinate: 25°10'34"N 92°23'46"E 907 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
04.10.2023	44.81	25.63	15.91	20.73
06.10.2023	47.17	23.60	17.67	22.02
10.10.2023	43.03	28.13	17.05	19.73
12.10.2023	44.90	25.63	19.67	22.72
14.10.2023	43.73	26.81	16.03	19.77
17.10.2023	41.88	22.47	15.71	20.69
19.10.2023	42.55	29.13	16.70	21.52
21.10.2023	40.73	26.63	15.25	20.66
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)
Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.				
 Analysed by		 Checked by		 Verified By

	MEGHALAYA POWER LIMITED (43MW) Lumshnong, Meghalaya		Reference No.	MPL/Env/F – 01
			Issue No.	1
			Date of Issue:	24.08.2013
			Revision No.	5
	AMBIENT AIR QUALITY MONITORING REPORT		Date of Rev.	01.12.2020
Reference No.: MPL (43 MW)/ENV/AAQM/MONTHLY/2023-24/07			Month : October	
Location of Sampling: Near STP		GPS Coordinate: 25°10'49"N 92°23'58"E 947 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
04.10.2023	26.18	20.59	16.27	22.25
06.10.2023	28.18	19.56	17.47	25.75
10.10.2023	29.50	21.89	14.79	18.38
12.10.2023	33.85	23.05	15.41	20.38
14.10.2023	31.47	21.41	16.09	22.25
17.10.2023	29.17	19.87	16.81	20.04
19.10.2023	33.40	17.40	16.09	21.28
21.10.2023	31.69	15.57	15.14	19.29
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)
Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.				
 Analysed by		 Checked by		 Verified By

	MEGHALAYA POWER LIMITED (43MW) Lumshnong, Meghalaya		Reference No.	MPL/Env/F – 01
			Issue No.	1
			Date of Issue:	24.08.2013
			Revision No.	5
AMBIENT AIR QUALITY MONITORING REPORT			Date of Rev.	01.12.2020
Reference No.: MPL (43 MW)/ENV/AAQM/MONTHLY/2023-24/07			Month : October	
Location of Sampling: Near Piezometer Well		GPS Coordinate: 25°10'35"N 92°23'53"E 348 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
04.10.2023	47.54	32.07	15.61	21.56
06.10.2023	46.16	26.65	17.15	20.36
10.10.2023	49.80	28.87	16.80	22.35
12.10.2023	51.30	32.55	14.73	21.22
14.10.2023	50.16	29.07	13.80	21.86
17.10.2023	44.51	30.72	14.80	20.82
19.10.2023	45.16	25.72	15.83	22.25
21.10.2023	41.78	24.71	13.15	22.34
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)
Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.				
 Analysed by		 Checked by		 Verified By

	MEGHALAYA POWER LIMITED (43MW) Lumshnong, Meghalaya		Reference No.	MPL/Env/F – 01
			Issue No.	1
	GROUND LEVEL AMBIENT AIR QUALITY MONITORING REPORT		Date of Issue:	24.08.2013
			Revision No.	5
			Date of Rev.	01.12.2020
Reference No.: MPL (43 MW)/ENV/AAQM/MONTHLY/2023-24/07			Month : October	
Location of Sampling: Near ADM Office		GPS Coordinate: 25°10'34"N 92°23'46"E 907 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
03.10.2023	39.21	21.19	13.80	17.90
05.10.2023	40.97	19.16	12.77	16.87
09.10.2023	37.43	23.69	15.10	19.20
11.10.2023	39.30	21.19	16.26	20.36
13.10.2023	38.13	22.37	16.80	18.72
16.10.2023	26.73	12.85	13.08	17.18
18.10.2023	36.95	24.69	14.37	17.91
20.10.2023	35.13	22.19	15.81	18.24
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)
Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.				
 Analysed by  Checked by  Verified By				

	MEGHALAYA POWER LIMITED (43MW) Lumshnong, Meghalaya		Reference No.	MPL/Env/F – 01
			Issue No.	1
	GROUND LEVEL AMBIENT AIR QUALITY MONITORING REPORT		Date of Issue:	24.08.2013
			Revision No.	5
			Date of Rev.	01.12.2020
Reference No.: MPL (43 MW)/ENV/AAQM/MONTHLY/2023-24/07			Month : October	
Location of Sampling: Near DM Plant		GPS Coordinate: 25°10'43"N 92°23'50"E 348 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
03.10.2023	34.97	23.40	16.27	19.98
05.10.2023	35.27	21.37	15.24	18.95
09.10.2023	36.38	25.90	17.57	21.28
11.10.2023	34.43	23.40	18.73	22.44
13.10.2023	32.94	24.58	17.09	20.80
16.10.2023	31.43	20.24	15.55	19.26
18.10.2023	32.95	26.90	11.62	16.79
20.10.2023	30.15	24.40	11.25	14.96
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)
Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.				
 Analysed by		 Checked by		 Verified By

	MEGHALAYA POWER LIMITED (43 MW) Lumshnong, Meghalaya		Reference No.	MPL/Env/F-02
			Issue No.	1
	STACK EMISSION MONITORING ANALYSIS REPORT		Date of Issue:	01.05.2019
			Revision No.	5
			Date of Rev.	01.06.2021
Report No: MPL(43MW)/ENV/STACK/MONTHLY/2023-24/07 Month: October				
<u>Analysis Result</u>				
A. General Information About Stack				
1	Stack Identification No			43 MW
2	Stack Connected to			Boiler
3	Material of Construction (Stack/Duct)			RCC
4	Shape of duct			Circular
5	Whether duct is provided with permanent platform & ladder			Yes
B. Physical characteristic of stack				
1	Stack Height from ground level (meter)			81.0
2	Duct diameter at sampling point (meter)			2.75
3	Sampling height point from ground level (meter)			45.5
4	Cross sectional area of Duct/Stack (m ²)			5.94
C. Pollution Control Device				
1	Details of pollution control device attached to stack			ESP
D. Result of Sampling & Analysis of Gaseous Emission				
1	Date of Sampling			19.10.2023
2	Ambient Temp (°C)			38
3	Stack Gas Temp (°C)			125
4	Exit Velocity of Gas (m/sec.)			13.8
5	Flow Rate (Nm ³ / sec.)			56.9
6	Quantity of Emission (Nm ³ / Hr)			204863.9
7	Concentration of PM (mg/Nm ³)			26.4
8	Concentration of SO ₂ (mg/Nm ³)			319
9	Concentration of NO _x (mg/Nm ³)			102
10	Oxygen (O ₂) (%)			9.7
E. Remarks:				
Standard				
PM - 50 mg/Nm ³		SO ₂ - 600 mg/Nm ³		NO _x - 300 mg/Nm ³
<i>Particulate Matter (PM), Sulphur di-oxide (SO₂), Oxide of Nitrogen (Nox), Electro Static Precipitator (ESP)</i>				
 Analysis by  Checked by  Authorized Signatory				

	MEGHALAYA POWER LIMITED Lumshnong, Meghalaya		Document No.	MPL/EHS/Env/F-04
			Date of Issued	01-05-2019
			Revision No.	2
	FUJITIVE EMISSION MONITORING REPORT		Revision Date	01-01-2021
Ref: MPL(43MW)/ENV/FUGITIVE/MONTHLY/2023-24/07				
Month - October				
Date	Location	Fugitive Emission Results	As per CPCB/BIS Guideline	
			Limit	
		(in $\mu\text{g}/\text{m}^3$)	(in $\mu\text{g}/\text{m}^3$)	
11.10.2023	Coal Storage Section	1247	2000	
 Analyzed By  Checked By  Verified By				

	MEGHALAYA POWER LIMITED Lumshnong, Meghalaya				Reference No.	MPL/EHS/F-04
					Issue No.	1
	WATER TESTING REPORT				Date of Issue:	24.08.2013
					Revision No.	3
				Date of Rev.	01.06.2019	
Reference No.: MPL/ENV/WATER/MONTHLY/2023-24/07					Date of sample collection: 10.10.2023	
					Date of Analysis: 10.10.2023 to 13.10.2023	
Sl.No.	Parameter	Unit	STP Inlet	STP Outlet	Standard Norms For Discharge of Environment Pollution (Notification Date: - 19th May 1993) & Consent To Operate vide letter no. MPCB/TB-900 (Pt-II)/2014- 2015/34 - dated Shillong, the 3rd Sep,2014	
1	pH	-	7.6	7.8	5.5 to 9.0	
2	Colour	Hazen	Colourless	Colourless	-	
3	Odour	-	Odourless	Odourless	-	
4	Chloride	mg/L	73	74.4	-	
5	Total Hardness as CaCO ₃	mg/L	51.0	52.2	-	
6	Suspended Solids	mg/L	60	17.0	100	
7	Total Dissolve Solids	mg/L	256	299	-	
8	Chemical Oxygen Demand	mg/L	170	55	250	
9	Biochemical Oxygen Demand (For 3 days at 27 °C)	mg/L	78	18.3	30	
10	Oil & Grease	mg/L	1.0	< 3.0	10	
11	Temperature	° C	25	25	Shall not exceed 5.0°C above the receiving water temperature	
12	Conductivity	µS/cm	477	559	-	
 Analysis By  Checked By  Verified By						


	MEGHALAYA POWER LIMITED Lumshnong, Meghalaya			Reference No.	MPL/EHS/F-04
				Issue No.	1
	WATER TESTING REPORT			Date of Issue:	24.08.2013
				Revision No.	3
			Date of Rev.	01.06.2019	

Reference No.: MPL/ENV/WATER/MONTHLY/2023-24/07				Date of sample collection: 10.10.2023	
				Date of Analysis: 10.10.2023 to 13.10.2023	

Sl.No.	Parameter	Unit	ETP Outlet	Standard Norms For Discharge of Environment Pollution (Notification Date:- 19th May 1993) & Consent To Operate vide letter no. MPCB/TB-900 (Pt-II)/2014-2015/34 – dated Shillong, the 3rd SEP, 2014.
1	pH	-	7.3	5.5 to 9.0
2	Suspended Solids	mg/L	29	100
3	Total Dissolve Solids	mg/L	304	-
4	Chemical Oxygen Demand	mg/L	40	250
5	Biochemical Oxygen Demand (For 3 days at 27 °C)	mg/L	18	30
6	Oil & Grease	mg/L	<3.0	10


Analysis By


Checked By


Verified By

